

**DATA SHEET**

**DISCHARGE NOZZLE - INERT SYSTEM**

PART NO : IH475

DWG.NO.:DP-5.8/MT-361

DATE :MAR 2021

REV : 01


SCALE : N.T.S

SHEET :1 OF 1

APPD. BY : DBS


**INTRODUCTION :-**

INERT NOZZLE WILL BE FIXED AT APPROPRIATE PLACE IN THE PROTECTED AREA. INERT GAS WILL BE DISCHARGED THROUGH THE ORIFICE. NUMBER OF ORIFICE AND SIZE OF ORIFICE DEPENDS ON THE DESIGN CALCULATIONS.




38 A/F

**TOP VIEW**



70

**ELEVATION**



**SECTIONAL VIEW**

**NOTE :**

1. TOLERANCE ON DIMENSION  $\pm 2$  mm, UNLESS OTHERWISE SPECIFIED.
2. ALL DIMENSIONS ARE IN "mm" UNLESS OTHERWISE SPECIFIED.

**TECHNICAL SPECIFICATION**

|     |                          |                           |     |                |                           |
|-----|--------------------------|---------------------------|-----|----------------|---------------------------|
| 01. | MANUFACTURER             | balawa.. AGNI CONTROLS    | 06. | DISCHARGE RATE | AS PER DESIGN REQUIREMENT |
| 02. | MATERIAL OF CONSTRUCTION | BRASS                     | 07. | WEIGHT         | 0.3 KG (APPROX)           |
| 03. | FINISHING                | NICKEL COATED             |     |                |                           |
| 04. | CONNECTION               | 3/4" BSP THREAD           |     |                |                           |
| 05. | ORIFICE                  | AS PER DESIGN REQUIREMENT |     |                |                           |

**IMPORTANT:**

AGNI CONTROLS RESERVES THE RIGHT TO CHANGE OR MODIFY WITHOUT PREVIOUS NOTICE ANY DATA OR SPECIFICATION DUE TO CHANGES OR MODIFICATION IN ORDER TO IMPROVE THE PRODUCTS / SYSTEM PRESENTED.



**AGNI CONTROLS**  
**CHENNAI**

NO.1, 6TH STREET, Dr.SUBBARAYAN NAGAR,  
KODAMBAKKAM, CHENNAI-600 024, INDIA.

PHONE : +91 44 2481 2420

E-MAIL : [engineering@agnicontrols.com](mailto:engineering@agnicontrols.com) WEBSITE : [www.balafire.com](http://www.balafire.com)

ISO 9001 - 2015  
CERTIFIED COMPANY